



Caleb Brett

230 Crescent Avenue
Chelsea, Ma.

NO. 6 FUEL OIL

Lab Reference	99940666	Classification	Tk 6
Vessel/Barge	B-105	Grade	#6 Fuel Oil
Client	Sprague	Terminal	Prov. RI
Date on Sample	10/17/04	Customer Ref #	
Date Tested	10/18/04	Tested by	AC

Tests	Method	Results	Unit of Measure
API Gravity @ 60°F	D-4052	13.2	API
Flash Point, PMCC	D-93B	210	Degrees F
Pour Point/Upper	D-97	-3/27	Degrees C/F
Sulfur Content	D-4294	0.937	Weight %
S&W Content	D-1796	0.20	Volume %
Viscosity	D-445	359.5	Cst
Viscosity @ 122F	D-2161	169.7	Sfs
Ash Content	D-482	0.026	Weight %
Heat of Combustion	D-240	18,537	Btu/lb
Gravity	Table 8	8.144	lb./gal
Heat of Combustion	D-240	150,965	Btu/Gal.
Nitrogen	D-5762	0.34	Weight %
Vanadium	D5863B	25	Ppm
Sodium	D5863B	9	Ppm
Water by Distillation	D-95	0.20	Volume %
Sediment by Extraction	D-473	0.04	Weight %
Asphaltenes	D-3279	2.1	Weight %
Conradson Carbon Residue	D-189	11.2	Weight %

Approved by _____
Albert Collin Jr.

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.